

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001**

No. F.6/DFS/MS/GH/2024/SZ/ 659
To

Dated: 25/10/2024

The Addl. Commissioner of Police (Lic/Unit),
1st Floor, P.S. Defence Colony,
New Delhi-110049.

Sub: Regarding issuance of FSC in r/o M/s Beyond Hotels located at A-91, Malviya Nagar, New Delhi 110017

Sir,

This is in reference with **MHA Portal ID 2024081612777 dated 27/09/2024 & 2024100415205 dated 07/10/2024** on the subject cited above. In this connection, it is to inform you that the premise have been inspected by officer concerned of this department on 25/10/2024 in the presence of Mr. Rohit Kumar (Manager) and observed that the Guest House is running in First, Second & Third Floor only. During the course of inspection, the following shortcoming observed were noticed:-

1. Smoke management system not provided as per clause 7.31 of UBBL -2016.
2. Kitchen at terrace level not allowed as per clause 7.31 of UBBL 2016.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

[Handwritten signature]