

Dated: 23/10/2024

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELH HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI

No. F6/DFS/MS/GH/WZ/2024/ 653

To,

The Joint Commissioner of Police, Licensing Unit, 1st floor, Police Station, Defence Colony, New Delhi. addlep.lic-dl@nic.in

Sub: - Inspection report in r/o M/s. Hotel Swathi (A unit of Duratuf Hospitality Pvt. Ltd.) Located at Property no. 25, Paschim Vihar Ext. Ordinance Depot, Near Metro Pillar No. 195, New Delhi-110063.

Sir,

This is in reference to the online application received through MHA portal vide ID-Online ID Online Application No.2023031703819 dated-25/09/2024, on the subject cited above. In this connection, it is to inform you that the premises was inspected by officer concerned of this department on 17/10/2024 in the presence Sh. Sher Singh (Manager) to check the fire safety arrangements/equipments provided in the building.

During the course of inspection, it was observed that the said guest house is running at first and second floor in a building comprised of basement + ground + 3 upper floors. Fire safety arrangements such as Fire Extinguishers, First Aid hose reels, Internal Hydrant, Automatic fire detection and alarming system, MOEFA, Public Address System & etc provided. However the following shortcomings were observed.

- 1. Main fire pump, capacity of 900lpm is provided but not functional.
- Exit Signages found removed.

In view of above Shortcomings, application of renewal of Fire safety Certificate cannot be considered at this stage & rejected. The licensing issuing authority/statutory authority is requested that premises should not be allowed to run till it provide all necessary fire arrangements.

Yours faithfully

Copy to: -

The Owner/ Occupier Hotel Swathi Located at Property no. 25, Paschim V Ordinance Depot, Near Metro Pillar No.195, New Delhi-110063.

2. The DHO, West Zone, MCD, Shivaji Enclave, Raja Garden, New Delhi-110027. Email Id: - (dhowest zone@gmail.com)