



No. F6/DFS/MS/School/NDZ/2024/ 743

Dated: 29/10/2024

To,

The Principal,
MCD Primary School
Harijan Basti Gharoli,
Delhi – 110096.

Subject: - Regarding grant of Fire Safety Certificate in r/o MCD Primary School located at Harijan Basti Gharoli, Delhi – 110096.

Sir,

This has a reference to email dated 20/09/2024, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 18/10/2024 in the presence of Mrs. Archana (Principal) and observed that building comprised of ground plus two upper floors (New Building only).

Following shortcomings were observed during time of inspection:

1. First-Aid-Hose Reel not provided.
2. Fire pump of 450 LPM not provided.
3. Over head water storage tank of-10,000 liters capacity is required exclusively for firefighting is not provided.
4. Exit & floors Signage's not provided in strategic location in the building.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

o/c
@

Copy to:-

1. The Dy. Director of Education, B Block, Yamuna Vihar, Delhi - 110053.