

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No. F.6 /DFS/MS/BP/2024/ 599

Dated: 28/10/2024

To,

The Executive Engineer (Bldg.) HQ,
Municipal Corporation of Delhi,
9th floor, Civic Centre, Minto Road,
New Delhi 110002.

Sub: Clearance from fire safety point of view in r/o Plot NO. – 28, Paschim Vihar Extn. New Delhi - 110063

Sir,


Please refer your online request ID No.-10119565 dated 22/10/2024, on the subject cited above. In this connection, it is to inform you that the building plans were scrutinized from fire safety point of view and observed that there is a proposal of new construction of building at Plot No. – 28, Paschim Vihar Extn. New Delhi - 110063

Following shortcoming is observed:

1. Staircases are not placed as per clause 7.8.3 of UBBL – 2016.
2. Exit doorways are not opening as per clause 7.12.5 of UBBL- 2016.
3. Exits are not proposed at stilt floor as per clause 7.5 of UBBL-2016.
4. Terrace pump is not proposed on plan as per NBC part-4,2016.
5. Exits are not proposed as per clause 7.6 of UBBL-2016.

Accordingly, the case is hereby rejected.

Yours faithfully,


(Atul Garg)
Director

011-23414000

u e w