

c/12

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI - 110001

NO. F6/DFS/MS/SZ/2024/94/654

DATED: 24/10/2024

To,

The Joint Commissioner of Police (Lic),
1st Floor, Licensing Unit, Police Station,
Defence Colony, New Delhi

Subject: - Renewal of Fire safety Certificate in r/o M/s Rupam Guest House, Located at 9A/35, WEA, Channa Market, Karol Bagh, New Delhi - 110005.

Sir,

Please refer to online application No. 2024092814947, dated 28/09/2024 on the subject mentioned above. In this connection it is submitted that the above said premises was visited by the officer concerned of this department on 21/10/2024 in the presence of Sh. Gurjit Singh (Owner) from fire safety point of view.

During the course of inspection following shortcomings are observed:

1. Ventilation system for upper floor found inadequate/ non functional.
2. MOEFA found nonfunctional.
3. PA system found nonfunctional
4. Exit signage found removed at some places.
5. Terrace floor shall not be use for any purpose.

In view of the above shortcomings renewal of Fire Safety Certificate from fire safety point of view cannot be considered at this stage. Applicant may be directed to comply the shortcomings under intimation to this department for further consideration in the matter

Yours faithfully,


(Atul Garg)
Director,
Delhi Fire Service

Copy to:-

1. The Executive Engineer (Building), MCD, Civic Centre, Minto Road, New Delhi.
2. The Manager, M/S Rupam Guest House, Located at 9A/35, WEA, Channa Market, Karol Bagh, New Delhi - 110005.