



No. F6/DFS/MS/School/NDZ/2024/ 742

Dated: 29/10/2024

To,

The Principal,
Spring Bales Public Sr. Sec. School
7 - 8, New Gobind Pura, Bhagat Singh Road,
Delhi - 110051.

Subject: - Regarding grant of Fire Safety Certificate in r/o Spring Bales Public Sr. Sec. School located at 7 - 8, New Gobind Pura, Bhagat Singh Road, Delhi - 110051.

Sir,

This has a reference to your Outdoor Dairy No. 7654 dated 09.10.2024, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 18/10/2024 in the presence of Mr. Raj Dixit (Manager) and observed that building comprised of ground plus three upper floors.

Following shortcomings were observed during time of inspection:

1. One single Staircase having width of 1.50 meters exists against the requirement of width of 1.50 meters. Hence, one additional staircase is required of width not less than 1.50 meters.
2. First-Aid-Hose Reel at each floors provided but not functional.
3. Fire pump of 450 LPM provided but not functional.
4. Over head water storage tank of 10,000 liters capacity required exclusively for firefighting is not provided.
5. Exit & floors Signage's not provided in strategic location in the building.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR

o/c DELHI FIRE SERVICE

Copy to:-

1. The Joint Director of Education, (Land & Estate), Lucknow Road, Delhi - 110054.
2. The Manager, Spring Bales Public Sr. Sec. School located at 7 - 8, New Gobind Pura, Bhagat Singh Road, Delhi - 110051.