



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



c/10

No.F6/DFS/MS/2024/EH/ 481
To

Dated 29/10/2024

The Joint Commissioner of Police/ Lic,
1st Floor, Licensing Unit, Police Station
Defence Colony, New Delhi.

Sub: - Regarding issuance of fire safety certificate in r/o M/s Badri Parshad Foods located at
Property No- E-90, Ground Floor, Kamla Nagar, Delhi-110007.

Sir,

This has reference to online mha portal I'd. No. 2024101115552 dated 15.10.2024 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 23.10.2024 in the presence of Mr. Darpan Gupta to verify the fire safety measures installed in the building and observed that the building is comprised of ground & 03 upper floors but restaurant is running at ground floor only. Your request for FSC is rejected under Rule 37 (3) due to following shortcomings.

- 1 Fire check door is not provided in the kitchen area.
- 2 There are two exit doors having width of 1.50m & 90cm is provided against the requirement of 1.50m each.
- 3 Smoke ventilation system is not provided.
- 4 Hose reel hose is not provided.
- 5 MOEFA is not provided.
- 6 Internal hydrant is not provided.
- 7 Terrace level fire fighting pump capacity of 450lpm is not provided.
- 8 Terrace level fire water tank capacity of 20,000ltrs is not provided.
- 9 Emergency exits signage's is not provided in the restaurant.
- 10 Standby power supply is not provided.

Keeping in view of above, grant of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of restaurant is at your own risk & responsibility.

Yours faithfully

(Atul Garg)
Director

Ph: 011-23414000

26/10