

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F.6/DFS/MS/EH/2024/SZ/483

Dated: 29 / 10 / 2024

To

The Addl. Commissioner of Police,
1st Floor PS Defence Colony,
New Delhi 110049

Sub: Regarding issuance of Fire Safety Certificate in r/o **M/s KFC Restaurant** located at **Ground Floor Shop No 1**, Gate No 2, Arjangarh Metro Station, New Delhi 110047


Sir,

This has reference to with **MHA Portal ID No 2024092214610** dated **22/09/2024** on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 24.10.2024 in the presence of Mr. Omkar Kumar (Fire Officer) to verify the present status of fire safety measures installed in the building. The fire safety arrangements were tested / checked and found following observations:-

1. Terrace level fire fighting pump capacity 450 LPM Not Provided.
2. Overhead water tank capacity 20,000 ltrs not provided.
3. Exit signage not provided.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

dm c