

c/50

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No.F6/DFS/MS/NDZ/ 2416

Dated: 28/10/2024

To,
The Fire Officer,
NDMC, Mezz. Floor, Sansad Marg,
Palika Kendra, New Delhi.

Sub: Issuance of FSC (Fire Safety Certificate) in r/o Mayur Bhawan, at Connaught Place, Near Shanker Market, New Delhi-01.

Sir,

This has reference to mail id fo@ndmc.gov.in dated 19.09.2024, on the subject cited above. In this regard, it is to inform you that the site was inspected by the officers concerned of this department on 22-10-2024 in the presence of Mr. Mahendra Shokeen, Fire Officer, NDMC and observed that shortcomings issued earlier vide letter no F6/DFS/MS/NDZ/2023/163 dated 30.01.2023 (copy enclosed) are still not complied in toto. Further, fire man switch also found nonfunctional.

Hence, Fire Safety Certificate (FSC) cannot be renewed at this stage. Therefore, you are requested to rectify all the shortcomings and re-submit for further consideration in the matter.

Yours faithfully,

Encl: As above.

(Atul Darg)
DIRECTOR
Delhi Fire Service

Copy to:

1. The Chief Architect, NDMC, Palika Kendra, New Delhi.

C-40
Ch8

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No.F.6/DFS/MS/NDZ/2023/163

Dated: 30/01/2023

To

Sh. N.K. Gaur, Fire Officer,
New Delhi Municipal Council,
Palika Kendra, New Delhi.

**Sub:- Regarding Fire Safety Certificate in r/o Mayur Bhawan at Connaught Place near
Shanker Market, New Delhi.**

Sir,

This has reference to your e-mail <fo@ndmc.gov.in> dated 10.01.2023, on the subject cited above. In this regard, it is to inform that the site was inspected by the officers concerned of this department on 18/01/2023 in the presence of yourself and the following shortcomings were still not complied.

1. Fire check door for compartmentation found replaced with normal glass door and fire check door in basement found broken also.
2. Smoke management system in basement found nonfunctional and not integrated with alarm system also.

In view of above shortcomings, request for renewal of fire NOC is rejected. The occupancy of building /premises, in absence requisite fire & life safety arrangements, shall be at the risk and liability of the owner/occupier. The statutory/licensing authority may take suitable action as deemed fit.

Yours faithfully

(Atul Garg)
DIRECTOR

Delhi Fire Service

Copy to:-

The Chief Architect, NDMC, Palika Kendra, New Delhi.