

C/74

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F6/DFS/MS/GH/NDZ/ 658

Dated: 25.10/2024

To,

The Manager,
M/s Nine Street Guest House at 9390,
Multani Dhanda, Pahar Ganj, New Delhi.

Sub: Regarding renewal of FSC in r/o M/S Nine Street Guest House at 9390, Multani Dhanda, Pahar Ganj, New Delhi

Sir,

This has reference to your online id no. ID NO. 2024100815419 dated 08.10.2024, on the subject cited above. In this regard, it is to inform you that the site was visited by the officer concerned of this department on dated 21/10/24 in presence of Mr. K.K. Singh and following shortcomings were observed:

1. Smoke management system is not provided.
2. CO detectors are not provided.

Hence, the case is rejected and Fire Safety Certificate (FSC) cannot be renewed at this stage due to above shortcomings. Therefore, you are requested to rectify the above shortcomings and re-submit for further consideration in the matter

Yours faithfully,

(Arul Garg)
DIRECTOR
Delhi Fire Service

Copy to :-

1. The Commissioner, MCD, Civic Centre, New Delhi.
2. The Addl. Commissioner of Police (Lic.) First floor, PS Defense Colony, New Delhi.