

c/s/o

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001

No. F.6/DFS/MS/GH/2024/SZ/ 655
To

Dated: 24/10/2024

The Addl. Commissioner of Police,
Lic/Branch, 1st Floor, P.S Defence Colony
New Delhi 110049.

Sub: Regarding renewal of FSC in r/o M/s UDMAN BY FERNS AND PETALS (Unit of FNP Weddings and Events India Pvt Ltd located at N-82, Panchshila Park, New Delhi- 17.

Sir,

This has reference with **MHA Portal ID 2024100715381 dated 07/10/2024** on the subject cited above. In this connection, it is inform you that the premise has been inspected by officer concerned of this department on 19.10.2024 in the presence of Mr. Mukesh Kumar to verify the present status of fire safety measures installed in the building. The fire safety arrangements were tested / checked and found following observations:-

1. Fire Check door found removed in the building.
2. Exit signage found removed at some places.

In view of above observation, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall not be allowed in the interest of public safety. The liability of any loss of life and property in case of any eventuality / misshape shall be lies with the owner/ occupier of the building.

Yours faithfully

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Atul G