



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

c-33

No: F.6/DFS/MS/School/2024/WZ/ 748

Dated: 01/11/2024

To,

Sh. Vikram Lakhotia,
Maheshwari Mandal (Delhi),
Maheshwari Bhawan, C Block,
Ashok Vihar, Phase-1, Delhi- 110052.

Sub: - Regarding issuance of Fire Safety Certificate in r/o "Bageecha", Maheshwari Public School located at C- Block, Ashok Vihar, Phase-1, Delhi- 110052.

Sir,

This has reference to your application no. Nil received through outdoor diary no. 7395 dated 04.10.2024 on the subject cited above. In this connection, it is to inform you that the inspection of above said school building has been carried out by officer concerned of this department on 21.10.2024 to see the compliance of the requisite fire safety measures. Smt. Malvika (Principal) was present at the time of inspection.

During the course of inspection it was observed that the school is running on Ground floor in a building comprised of Ground and Mezzanine floor. Your request for issuance of FSC is rejected as the following shortcomings were observed:-

1. Door width found 1.05 m against the required width of 1.20 m.
2. Building plan on 1:100 scale from a registered architect not provided.
3. Electric meter and electrical panel near exit shall be removed to a safer place.
4. Form 'I' and school performa not provided.

You are advised to rectify the above-mentioned shortcoming for taking further action as necessary for issuance of Fire Safety Certificate.

Yours Faithfully

(Atul Garg)
Director

Ph/011-23414000

Copy to:-

1. Director of Education, Govt. Of NCT of Delhi, Old Secretariat, New Delhi.

29/10