



c/44

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/2024/CC/ 355

Dated: 0 / 11/2024

To

The Director (DICS)
At Plot No-01, Ground Floor,
HudsonLine, Kingsway Camp, Delhi-09.

Sub: - Regarding issuance of Fire Safety Certificate in r/o DICS (Coaching Centre) Plot No-01, Ground Floor, Hudson Line, Kingsway Camp, Delhi-110009.

Sir,

Please refer to your letter no. nil dated 19.10.2024 received in this department vide outdoor diary no. 8053 dated 21.10.2024 on the subject cited above. In this connection this is to inform you that the above mentioned site was visited by the officer concerned of this department on 22.10.2024 to verify the fire safety arrangements installed in the building as per issued fire safety recommendations vide letter of even no. F6/DFS/MS/2019/BP/57 dated 08.02.2019 at the time of inspection Dr. Sanjay Nijhawan was also present at site. During the course of the inspection it is observed that the building is comprised of basement, ground & 03 upper floors but coaching center proposed at ground floor only. Your request for FSC is rejected under Rule 37 (3) due to following shortcomings.

1. There are two exits door is provided having width of 1.50m & 90cm against the requirement of 1.50m each.
2. Smoke management system is not provided.
3. Fire extinguisher is not provided.
4. Hose reel hose is not provided.
5. Terrace level fire pump capacity of 450lpm is not provided.
6. Terrace level fire water tank capacity of 10, 000ltr is not provided.
7. Exit & floor signage's is not provided at strategical location in the building.
8. Standby power supply is not provided.

Keeping in view of above, grant of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the abovementioned shortcomings under intimation to this department; till such time running of educational building (coaching centre) is at your own risk & responsibility.

Yours faithfully/

(Anil Garg)
Director

Ph:-011-23414000

Copy to:-

1. The Executive Engineer (Bldg.)-I, Rajpura Road, Civil Line Zone, Delhi.

28/10