



No. F6/DFS/MS/School/NDZ/2024/747

Dated: 16/11/2024

To,

The Principal,
Dreamland Public School
A - Block, Rajiv Nagar, Mandoli,
Delhi - 110093.

Subject: - Regarding grant of Fire Safety Certificate in r/o Dreamland Public School located at A - Block, Rajiv Nagar, Mandoli, Delhi - 110093.

Sir,

This has a reference to your Outdoor Dairy No. 7611 dated 08/10/2024, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 18/10/2024 in the presence of Mr. S. P. Gautam (Manager) and observed that building comprised of ground plus two upper floors.

Following shortcomings were observed during time of inspection:

1. Two staircase of width 1.22 & 1.20 meter are provided instead of required width of 1.50 meters each.
2. Fire Extinguishers not provided.
3. First-Aid-Hose Reel at each floors found removed.
4. Fire pump of 450 LPM found removed.
5. Over head water storage tank of 10,000 liters capacity is required exclusively for firefighting is not provided.
6. Exit & floors Signage's not provided in strategic location in the building.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR

o/c DELHI FIRE SERVICE

Copy to:-

1. The Dy. Director of Education, B - Block, Yamuna Vihar, Delhi - 110053.
2. The Manager, Dreamland Public School located at A-Block, Rajiv Nagar, Mandoli, Delhi - 110093.