

C/37

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE

NEW DELHI- 110001

No. F6/DFS/MS/School/2024/SZ/ 745

Dated: 30/10/2024

To,

The Principal,
Govt. Girls Sr. Sec. School,
Goela Khurd, New Delhi-110071.

Sub: -Regarding renewal of "FSC" from fire safety point of view in r/o Govt. Girls Sr. Sec. School, Goela Khurd, New Delhi-110071.

Sir,

Please refer to your letter received through online email Id goela1822257@gmail.com dated 04.10.2024, on the subject cited above. In this connection, it is to inform you that officer concerned of this department inspected the school building on dated 21.10.2024 in the presence of Sh. Sunil Kumar (Estate Manager)), to verify the fire safety arrangements in accordance with the rules.

At the time of inspection, it was observed that the school building comprised of ground plus three upper floors and following shortcomings were observed: -

1. Hose reels/hydrant provided but found not functional
2. Terrace Fire pump provided but found not functional.
3. Exit signage's are found removed at some places.

In view of the above, fire safety certificate cannot be considered at this stage. Therefore, you are suggested to rectify the above said shortcomings under the intimation to this department for further necessary action in the matter and running school in absence of requisite fire safety arrangements shall be at the risk & liability of the owner/occupier.

Yours faithfully


(Atul Garg)
Director
Delhi Fire Service
ev.

Copy to:-

1. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.

: - for necessary action please.