

c/22

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001

No. F6/DFS/MS/School/2024/SZ/ 746

Dated: 30/10/2024

To,
The Principal,
M.C. Primary Boys School, Baprola No.-1,
Jai Vihar-I (1st & 2nd Shift), New Delhi-110043.

Sub: -Regarding renewal of "Fire Safety Certificate" from fire safety point of view in r/o M.C. Primary Boys School, Baprola No.-1, Jai Vihar-I (1st & 2nd Shift), New Delhi-110043.

Sir,

Please refer to your letter No. Nil, dated 19.09.2024, on the subject cited above. In this connection, it is to inform you that officer concerned of this department inspected the school building on dated 21.10.2024 in the presence of Sh. Jitender Singh (Principal), to verify the fire safety arrangements in accordance with the rules.

At the time of inspection, it was observed that the school having two blocks namely Old block comprised of ground plus one upper floor and New block comprised of ground plus three upper floors. Earlier FSC issued by this department vide letter No. F.6/DFS/MS/School/2021/SZ/702 dated 03.09.2021 for old block (G+1) only but now school having new block comprised of ground plus three upper floors, Therefore, following shortcomings were observed: -

1. Hose reels/hydrant found not provided in new block
2. Terrace Fire pump capacity of 450 LPM found not provided in new block.
3. Overhead water storage tank capacity of 10,000 ltrs found not provided in new block.
4. Exit signage's are found not provided.

In view of the above, fire safety certificate cannot be considered at this stage. Therefore, you are suggested to rectify the above said shortcomings under the intimation to this department for further necessary action in the matter and running school in absence of requisite fire safety arrangements shall be at the risk & liability of the owner/occupier.

Yours faithfully


(Atal Garg)
Director
Delhi Fire Service

Copy to:-

1. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.

: - for necessary action please.