

a-05

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/SZ/2024/ EH | 486

Dated: 01 / 11 / 2024

To,

The Addl. Commissioner of Police (Lic),
1st Floor, Licensing Unit, Police Station,
Defence Colony, New Delhi.

Subject: Issuance of Fire Safety Certificate from fire safety point of view in r/o M/s Breeze 7 Open Air Café Private limited Located at 3rd floor Vardhman Star no 351 city mall LSCIII Sector 7 Dwarka New Delhi-110045.

Sir,

Please refer to online application No. 2024090413698 dated-04/09/2024 on the subject mentioned above. In this connection it is to inform you that the premise was inspected by the officer concerned from this department on 21/10/2024 in the presence of Sh. Jamashir Singh from fire safety point of view.

During the course of inspection the following shortcomings are observed.

1. Two stairs of 1.5m clear width found not provided.
2. Two Exits of 1.5 M clear width found not provided
3. Automatic fire detection system found not provided.
4. Manually operated fire alarm system found not provided.
5. Hose reel hose & hydrants found not provided.
6. Main Pump and stand by pump of 2280lpm & jockey pump of 180lpm s at ground found not provided.
7. Terrace fire pump of 900lpm found not provided.
8. Underground tank of capacity 150000 ltr not provided.
9. Overhead tank of capacity 10000 ltr not provided.
10. Exit signage found not provided at some places.
11. Basement found locked could not be inspected.

In view of the above shortcomings renewal of Fire Safety Certificate from fire safety point of view cannot be considered. Applicant may be directed to comply the shortcomings under intimation with this department for further consideration in the matter.

(Atul Garg)
Director
Delhi Fire Service

Ok
23/10/24

Copy to: -

1. The Executive Engineer (Building), MCD, Civic Centre, Minto Road, New Delhi.
2. The Manager, M/s Breeze 7 Open Air Café Private limited Located at 3rd floor Vardhman Star no 351 city mall LSCIII Sector 7 Dwarka New Delhi-110045.