

e56



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/WZ/2024/CC | 357
To,

Dated: 04/11/2024

Dr. Ram Kailash Gupta,
Dr. Ram Kailash Gupta & Mrs. Kusum Gupta
(Coaching Institute), B-71/2,
Wazirpur Industrial Area, Delhi-110052.

Sub: - Inspection report in r/o M/s. Dr. Ram Kailash Gupta & Mrs. Kusum Gupta Coaching Institute, located at B-71/2, Wazirpur Industrial Area, Delhi- 110052.

Sir,

This is in reference to your e mail id dated 08/10/2024 on the subject cited above. In this connection, it is to inform you that the above said building was re-inspected by the officer concerned by this department on 26/10/2024 in the presence of Smt. Saraswati Sharma (Principal) to see the compliance of shortcomings communicated vide this department letter no. F6/DFS/MS/2024/WZ/489 dated 02/09/2024.

The status of shortcoming is as under:-

Sr. No	Shortcomings	Status
1.	Two stairs of width 1.35 m to 1.5 m & 1.40 m to 1.5 m found provided against the requirement of two staircases of width 1.5 m each.	Rectified
2.	Two stairs of width 1.30 m to 1.40 m & 1.50 m found provided against the requirement of two staircases of width 1.5 m for basement.	Not Rectified
3.	Fire check door is not provided in basement.	Rectified
4.	Smoke ventilation system is not provided in basement.	Not Rectified
5.	Sprinkler is not provided in left out area in basement.	Not Rectified
6.	Terrace level pump not found in auto mode.	Rectified
7.	Inspection ladder is not provided.	Rectified
8.	Floor level signage and exit signage are not provided.	Rectified
4.	Electrical panels installed inside the staircase must be removed.	Rectified

In view of the above shortcomings, the application for renewal of Fire Safety Certificate is not considered at this stage & rejected. The occupancy of the Building/ premises in absence of requisites fire safety arrangements shall be at your risk and responsibility due to any mishap/ loss of life in the building.

Yours faithfully,


(Atul Gang)
Director
Delhi Fire Service

De R

7/30/11

Copy to :-

1. The Executive Engineer (Bldg.), MCD, Keshavpuram Zone, Keshavpuram, New Delhi- 110034, take necessary action at your end being competent authority.
2. The, SHO, Wahirpur Police Station, Wazirpur, Delhi- 110052, for necessary action.