



No. F6 /DFS/MS/GH/NDZ/2024/ 669

Dated: 29/10/2024

To,

The Manager  
Sidak Residency  
Property no. 186, Saini Enclave Shahdara,  
Delhi - 110092.

**Sub: - Regarding grant of Fire Safety Certificate in r/o M/s Sidak Residency located at Property no. 186, Saini Enclave Shahdara, Delhi – 110092.**

Sir,


This has a reference to your outdoor diary no. 8424 dated 08/11/2024, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 23/10/2024 in the presence of Mr. Siddharth Jain (Owner) and observed that building comprised of Basement (Found Closed), Stilt (Parking + Reception) + Upper ground plus three upper floors only. Inspection in basement couldn't be carried out.

**Following shortcomings were observed during time of inspection:**

1. The width of corridor is 1.45 meter & 1.0 meter is available against the requirement of 1.80 meter.
2. Smoke Management System not provided in upper floors.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

  
(ATUL GARG)  
DIRECTOR  
DELHI FIRE SERVICE  
OK @ 20

**Copy to: -**

1. The Commissioner of Police (Lic.) 1<sup>st</sup> floor, Police Station Defence Colony, New Delhi - 24.