

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No. F.6/DFS/MS/GH/2024/SZ/ 670

Dated: 01 / 11 / 2024

To

The Joint Commissioner of Police (Lic/Branch)
1st Floor, Police Station Defence Colony,
New Delhi 110049

Subject: Regarding issuance of Fire Safety Certificate in r/o M/s The Orion Express
(A Unit of Orion hotels Pvt Ltd) at D-150, East of Kailash, New Delhi-48

Sir,

This has reference with **MHA Portal ID 2024093015052 dated 01/10/2024** on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 29/10/2024 in the presence of Mr. Alimesh Kumar to verify the present status of fire safety measures installed in the building. The fire safety arrangements were tested / checked and found following observations:-

1. The Fire Check door is not provided in rear side.
2. First Aid Hose Reel provided but found non-functional.
3. Automatic Sprinkler System provided but found non-functional.
4. Fire fighting pumps are not on auto mode.
5. Basement is use for banquet Hall is not allowed. Hence, the MCD Building department is hereby requested to verify the facts and take action in the matter as deemed fit.

The same observations has already been issued and communicated earlier by this department vide letter of even no 587 dated 18/09/2024 & letter of even no 483 dated 14/08/2024.

In view of above observation, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall not be allowed in the interest of public safety. The liability of any loss of life and property in case of any eventuality / misshape shall be lies with the owner/ occupier of the building.

Yours faithfully,

(ATUL KARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to:-

1. The Dy. Commissioner, (Central Zone) Municipal Corporation of Delhi, Jal Vihar Lajpat Nagar, New Delhi 110024 with request to take action in the matter please.