

288

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI- 110001**

No. F6/DFS/MS/WZ/EH/2024/ 496

Dated: 05/11/2024

To,

The Joint Commissioner of Police,  
Licensing Unit, 1<sup>st</sup> floor, Police Station,  
Defence Colony, New Delhi.  
[addlcp.lic-dl@nic.in](mailto:addlcp.lic-dl@nic.in)

Sub: - Inspection report in r/o M/s. Boussac (A Unit of NG Warehouse Pvt. Ltd.) Located at shop/property No. 13-C, Third Floor, NWA, Club Road, West Punjabi Bagh, New Delhi - 110026.

Sir,

This is in reference to the online application received through MHA portal vide online ID No. 2024101815847 dated 18/10/2024, on the subject cited above. In this connection, it is to inform you that the premises was re-inspected by officer concerned of this department on 24/10/2024 in the presence Sh. Tarun Kumar (Manager) to check the shortcomings already issued by this deptt. vide letter No.- F6/DFS/MS/WZ/EH/2024/417 dated: 25/09/2024.

During the course of inspection, it was observed that the said restaurant is running at third floor in a building comprised of basement + stilt +ground + 3 upper floors. Fire safety arrangements such as Fire Extinguishers, First Aid hose reels, Internal Hydrant, MOEFA, & etc provided. However, the following shortcomings were observed.

However, the status of shortcomings is as under.

S. No.	Shortcomings	Status
1.	First Aid Hose Reel is provided but not functional.	Not Rectified
2.	MOEFA is provided but not functional.	Rectified
3.	Internal Hydrant is provided but not functional.	Not Rectified
4.	Main pump capacity of 2280 LPM, Jockey pump capacity of 180 LPM, Standby pump capacity of 2280 LPM & terrace level pump capacity of 450 LPM are provided but not functional.	Not Rectified (Jockey pump capacity of 180 LPM is found removed)
5.	Over head water storage tank capacity of 5000 ltrs is provided but found empty	Not Rectified
6.	Exit Signages found removed.	Rectified

In view of above Shortcomings the application for renewal of Fire Safety Certificate is not considered at this stage & rejected. The licensing issuing authority/statutory authority is requested that premises should not be allowed to run till it provide all necessary fire arrangements.

Yours faithfully,

(Atul Garg)  
Director

Copy to: -

- The Owner/Occupier, M/s. M/s. Boussac (A Unit of NG Warehouse Pvt. Ltd.) Located at shop/property No. 13-C, Third Floor, NWA, Club Road, West Punjabi Bagh, New Delhi - 110026.
- The DHO, West Zone, MCD, Shivaji Enclave, Raja Garden, New Delhi-110027. Email Id : - ([dhowestzone@gmail.com](mailto:dhowestzone@gmail.com)).