



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

c6
7/11/24
आपदा निवारण
अमृत महोत्सव

No. F6 /DFS/MS/EH/SZ/2024/ 497

Dated: 06/11/2024

To

The Joint Commissioner of Police,
Office of Joint commissioner of Police: Licensing,
1st Floor, P S Defence Colony, New Delhi.

Sub: -Regarding grant of Fire Safety Certificate in r/o M/s Jawahar Restaurant located at L-37, Ground floor, Lajpat Nagar, New Delhi.

Sir,

with reference to the etl.mcdonline application ID no. 2024102115950 on the subject cited above, it is informed that the said restaurant was inspected officer concerned from this department on 30.10.2024 in the presence of manager and it was observed that the restaurant is running at ground floor of the building which is comprised of Basement + Ground + 02 upper floors. During the inspection following shortcomings were observed:

1. Alternate exit having width 1.50 meter shall be provided.
2. Overhand tank capacity of 20,000 liters for firefighting shall be provided.
3. Fire pump not in auto mode.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Atul Garg)
Director
Delhi Fire Service

9/11/24