

C/ISS

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No. F.6/DFS/MS/GH/2024/SZ/672

Dated: 05 / 11 / 2024

To

The Joint Commissioner of Police (Lic/Branch)
1st Floor, Police Station Defence Colony,
New Delhi 110049

Subject: Regarding issuance of Fire Safety Certificate in r/o M/s JPM Hotel Majestic Guest House, at D-52, East of Kailash, New Delhi 110065

Sir,

This has reference with **MHA Portal ID 2024100615306 dated 06/10/2024** on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 01/11/2024 in the presence of Mr. Sarfaraj (Manager) to verify the present status of fire safety measures installed in the building. The fire safety arrangements were tested / checked and found following observations:-

1. The Fire Check door found removed.
2. First Aid Hose Reel provided but found non-functional.
3. Automatic Sprinkler System provided in basement but found non-functional.
4. Fire fighting pumps are not working.

In view of above observation, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall not be allowed in the interest of public safety. The liability of any loss of life and property in case of any eventuality / misshape shall be lies with the owner/ occupier of the building.

Yours faithfully,


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE