

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F-6/DFS/MS/EH/SZ/2024/494

Dated 05/11/2024

To,

The Joint C.P. (LIC.),  
 1<sup>st</sup> floor, Police Station,  
 Defense Colony, New Delhi.

Sub: - Regarding issuance of fire safety certificate in r/o M/s. McDonald (A unit of Connaught Plaza Restaurants Pvt Ltd. Located at Plot No. 4,5 & half of Plot-3, Main Najafgarh Road, Uttam Nagar, New Delhi- 110059.

Sir,

Please refer to online application ID 2024101115541 dated 11.10.2024, on the subject cited above. In this connection, it is to inform you that the above said eating house running at ground and first floor of a building comprised of basement (storage), ground plus three upper floors (second and third floor are vacant). The above said assembly building (Restaurant) was inspected by the officer concerned of this department from safety point of view on dated 24.10.2024 in presence of Sh. Subodh Tyagi (Owner/occupier).

During the course of inspection, the following shortcomings have been observed: -

- 1 Two staircases having width of 1.40 to 1.45 & 1.20 to 1.30 m found provided against requirement of two staircases having width of 1.50 m each.
- 2 Fire Check Doors are not provided in kitchen.
- 3 Ventilation system found not provided in restaurant.
- 4 First Aid hose reel/hydrant found provided but not functional.
- 5 MOEFA provided but found not functional.
- 6 Sprinkler provided entire restaurant but found not functional
- 7 Exit signage found not provided.

Keeping in view of above, issuance of fire safety certificate cannot be considered at this stage. Restaurant management may be requested to rectify the above said shortcomings for taking further necessary action in this matter under intimation to this department.

Yours faithfully

  
 (Atal Garg)  
 Director  
 Delhi Fire Service

Copy to-

1. The Owner/Occupier, M/s. McDonald (A unit of Connaught Plaza Restaurants Pvt Ltd. Located at Plot No. 4,5 & half of Plot-3, Main Najafgarh Road, Uttam Nagar, New Delhi- 110059.
2. Executive Engineer (Bldg.), MCD, West Zone, Dr. Sahib Singh Varma Nigam Bhawan, Second Floor, Shivaji Enclave, New Delhi-110027

: - for information regarding use of basement.