



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F.6/DFS/MS/EH/2024/SZ/495

Dated: 05/11/2024

To

The Joint Commissioner of Police (Lic.),  
1<sup>st</sup> Floor, P.S. Defense Colony  
New Delhi-110049

**Sub: Inspection report in r/o M/s Sagar Ratna Restaurant situated at Shop No. 23 & 38,  
Ground Floor, DLF South Square Mall, Sarojini Nagar, New Delhi-110023**

Sir,

This has reference to online MHA ID No. 20240101615739 dated 16/10/2024. In this connection, it is to inform you that the said premise was visited by the officer concerned of this department on dated 29/10/2024 to verify status of the fire safety arrangements provided in the presence of Mr. Ravi (Manager). During the inspection, the shortcomings observed are as below.

1. Two of the entry/exit gates found encroached/obstructed.
2. MOEFA/MCPs panel found non-functional.
3. Exit signage found removed at some places.

In view of the above, the application for renewal of fire safety certificate is rejected. The occupancy of the premises in the absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The local/licensing authority may take suitable necessary action as deemed fit.

Yours faithfully,

  
(ATUL GARG)  
DIRECTOR  
DELHI FIRE SERVICE

Copy to: -

1. Medical Officer of Health, New Delhi Municipal Council, Licensing Department, Palika Kendra, New Delhi-110001
2. Sh. Uday Kumar, M/s Sagar Ratna Restaurant situated at Shop No. 23 & 38, Ground Floor, DLF South Square Mall, Sarojini Nagar, New Delhi-110023