

c/52

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI – 110001

No.F.6/DFS/MS/SZ/2024/SCHOOL/755

Dated: 05/11/2024

To,

The Principal,
Vandana Kindergaten School run by Krishna geetanjali foundation society (Regd.)
Sector – 10, Phase – 1, Dwarka, New Delhi – 110075.

Subject: Renewal of Fire Safety Certificate in r/o Vandana Kindergaten School run by Krishna geetanjali foundation society (Regd.) Located at Sector – 10, Phase – 1, Dwarka, New Delhi – 110075.

Sir,

Please refer to your letter No. VKGS/2024/251, dated – 14/10/2024 on the subject mentioned above. In this connection it is to inform you that the premises was inspected by the officer concerned from this department on 28/10/2024 in the presence of Sh. Triambic Singh (Estate Manager) from fire safety point of view.

The following shortcomings are observed during the time of inspection:-

1. Hose reel hose & hydrants found non functional.
2. Automatic sprinkler system found nonfunctional in basement.
3. Pumps at terrace level found nonfunctional.
4. Overhead tank of 15000 ltr capacity found replaced by 5000 ltr capacity tank.
5. Exit signage's found removed at some places.
6. School activities are noticed in basement. The basement must be used as per BBL.
7. Passage to second staircase found blocked.

In view of the above shortcomings renewal of Fire Safety Certificate from fire safety point of view cannot be considered. The applicant is directed to comply all the shortcomings under intimation to this department for further consideration in the matter.

Copy to; -

1. The, Directorate of Education Old Secretariat Delhi – 110054.
2. The Joint Director Bld, DDA Vikas Sadan INA, New Delhi for information w.r.t use of basement.
3. The Executive Engineer (Building), MCD, Civic Centre, Minto Road, New Delhi.


(Atul Garg)
Director
Delhi Fire Service.

dc
28/10/24