



No. F6/DFS/MS/GH/NDZ/2024/ 686

Dated: 13 /11/2024

To,

The Joint Commissioner of Police (Lic.),  
1<sup>st</sup> floor, Police Station Defence Colony,  
New Delhi – 110024

**Subject: - Regarding grant of Fire Safety Certificate in r/o Adimurti Foods and Beverages Pvt. Ltd located at Property no. 1/49, First, Second and third floor Lalita Park, Laxmi Nagar, Main Vikas Marg, Delhi - 110092.**

Sir,

This has a reference to MHA application No. 2024101415645 dated 15.10.2024, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 04/11/2024 in the presence of Mr. Arjun Munjral (Owner) and observed that building comprised of Basement (Closed) + Ground floor (Vacant) + three upper floors only. **(Guest House running on first, second & third floors only)**

**Following shortcomings were observed during time of inspection:**

1. Two staircase of width 1.45 meters & 1.50 meters are provided instead of required width 1.50 meters each.
2. Smoke Management System not provided in upper floors.
3. First-Aid-Hose Reel at each floors provided but not functional.
4. Internal Hydrant provided but not functional.
5. Fire pump of 450 LPM provided but not functional.
6. Exit & floors Signage's not provided in strategic location in the building.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

  
(ATUL GARG)  
DIRECTOR  
o/c DELHI FIRE SERVICE  
①

Copy to:-

1. The Owner, Adimurti Foods and Beverages Private Limited located at Property no. 1/49, Lalita Park, Laxmi Nagar, Main Vikas Marg, Delhi – 110092.