

c/15

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No.F6/DFS/MS/GH/NDZ/685

Dated:-13.11.2024

To,
The Manager,
M/S Namaste Hindustan , 4210,
Tel Mandi, Paharganj , New Delhi.

Sub: Issuance of FSC (Fire Safety Certificate) in r/o M/S Namaste Hindustan, 4210, Tel Mandi, Paharganj , New Delhi.

Sir,

This has reference to on-line ID No 2024102015907 dated 20/10/24.on the subject cited above. In this regard, it is to inform you that the site was inspected by the officers concerned of this department on 08/11/24 in the presence of Caretaker and following shortcomings were observed: -

1. FCD is not provided in basement at staircase and lift lobby.
2. Smoke management is not provided in basement and upper floors.

In view of above, Fire Safety Certificate (FSC) cannot be issued at this stage. Therefore, you are requested to rectify the above shortcomings and re-submit for further consideration in the matter.

Yours faithfully,


(Atul Garg)
DIRECTOR
01123414000
A W S
11/11

Copy to:-

1. The Addl. Commissioner of Police (Lic.) First floor, PS Defence Colony New Delhi.