



Dated: 13/11/2024

No. F6/DFS/MS/EH/NDZ/2024/ 506

To,

The Joint Commissioner of Police (Lic.),  
1<sup>st</sup> floor, Police Station Defence Colony,  
New Delhi - 110024

**Subject: - Regarding grant of Fire Safety Certificate in r/o M/s Captain Katora A unit of India Core Kitchen located at Property No. C- 10/28, Ground and first floor Main 100 Foot Road, Kabir Nagar, Shahdara, Delhi - 110094.**

Sir,

This has a reference to MHA Portal application No. 20244101415650 dated 15/10/2024 on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 04/11/2024 in the presence of Mr. Kamal Sharma (Owner) and observed that building comprised of Basement (store) + Stilt (Parking) + Upper ground plus three upper floors. **(Restaurant running on upper ground & first floor only)**

**Following shortcomings were observed during time of inspection:**

1. The width of door size is 0.92 meter & 1.30 meters against the requirement of 1.50 meter each.
2. Fire check door not provided.
3. Smoke Management System not provided in upper floors.
4. Exit & floors Signage's not provided at strategic location in the building.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)  
DIRECTOR

o/c DELHI FIRE SERVICE

Copy to:-

1. Mr. Owner, Captain Katora A unit of India Core Kitchen located at Property No. C- 10/28, Ground and first floor Main 100 Foot Road, Kabir Nagar, Shahdara, Delhi - 110094.