

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI – 110001

c/sy

NO. F6/DFS/MS/CGHS/SZ/2024/ 2483

DATED: 05/11/2024

To,

The President,
DDA Engineers CGHS Ltd
Plot no -26, Sector - 04, Dwarka,
New Delhi.

Subject: - Renewal of Fire safety Certificate from fire safety & means of escape point of view in r/o DDA Engineers CGHS Ltd located at Plot no -26, Sector - 04, Dwarka, New Delhi.

Sir,

Please refer to your letter No nil dated 06/10/2024 on the subject mentioned above. In this connection it is to inform you that the above said premise was visited by the officer concerned of this department on 29/10/2024 to see the compliance of the shortcomings communicated vide this office letter No. F6/DFS/MS/CGHS/SZ/2023/1886, dated 04/09/2023 and found that the shortcomings are still not fully complied.

In view of the above shortcomings renewal of Fire Safety Certificate from fire safety point of view cannot be considered at this stage. You are directed to comply all the shortcomings under intimation with this department for further consideration in the matter. The occupancy of the building premises without valid Fire Safety Certificate is on the risk and responsibility of the management committee

Yours faithfully,


(Anil Gang)
Director,
Delhi Fire Service.
ok

Copy to: - The Joint Director (Building), DDA, Vikas Sadan, INA, New Delhi.

C/47

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI - 110001

NO. F6/DFS/MS/CGHS/SZ/2023/ 1886

DATED: 04/09/2023

To,

The Authorized Signatory,
DDA Engineers CGHS Ltd
Plot no -26, Sector - 04,
Dwarka, New Delhi.

Subject: - Renewal of Fire safety Certificate from fire safety & means of escape point of view in r/o DDA Engineers CGHS Ltd located at Plot no -26, Sector - 04, Dwarka, New Delhi.

Sir,

Please refer to your letter No.nil dated 05/08/2023 on the subject cited above. In this connection it is to inform to you that the above said premises was re-inspected by the officer concerned of this department on 29/08/2023 in the presence of : Mr Shambhu Chaudhary (Security Supervisor) from fire safety point of view.

During the course of inspection followings shortcoming have been observed:-

1. Hose Reels & Hydrants system found nonfunctional.
2. PA system found nonfunctional.
3. MOEFA found Non functional.
4. All the Pumps at terrace level found nonfunctional.
5. Pumps at Ground level are not scene during inspection.
6. Exit signage found removed at some places.
7. Communication system in lift car found provided but nonfunctional.

You are requested to comply the abovementioned shortcomings under intimation to this department.

In view of the above shortcomings Fire Safety Certificate cannot be considered at this stage.

Yours faithfully,

(Atul Garg)
Director

Delhi Fire Service

Copy to:-

1. The Joint Director, DDA, Vikas Sadan, INA, New Delhi.