

C/1103

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001**

No.F6/DFS/MS/GH/NDZ/ 2024/682

Dated:-12.11.2024

To,

The Manager,  
Delhi Continental Guest House, 8218-19,  
Arakashan Road, Pahar Ganj,  
New Delhi.

**Sub: Regarding renewal of FSC in r/o M/S Delhi Continental Guest House, 8218-19,  
Arakashan Road, Pahar Ganj, New Delhi.**

Sir,

This has reference to your online id no. 2024101515704 dated 18/10/2024, on the subject cited above. In this regard, it is to inform you that the site was visited by the officer concerned of this department on dated 06/11/24 in presence of Sh. Amit Pal, Manager and following shortcomings were observed:

1. CO detectors found non functional.
2. No. of rooms mention in the application form does not match with building plan.

Hence, the case is rejected and Fire Safety Certificate (FSC) cannot be renewed at this stage due to above shortcomings. Therefore, you are requested to rectify the above shortcomings and re-submit for further consideration in the matter

Yours faithfully,

(Atul Garg)  
DIRECTOR  
Delhi Fire Service

**Copy to :-**

1. The Addl. Commissioner of Police (Lic.) First floor, PS Defense Colony, New Delhi.