



No. F6/DFS/MS/School/NDZ/2024/ 770

Dated: 14/11/2024

To,

The Principal,
Imperial Public School,
C - 73, Gali No. 09, Main Brijpuri Road,
Old Mustafabad, Delhi – 110094.

Subject: - Regarding grant of Fire Safety Certificate in r/o Imperial Public School located at C - 73, Gali No. 09, Main Brijpuri Road, Old Mustafabad, Delhi – 110094.

Sir,

This has a reference to Email dated 26/10/2024, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 04/11/2024 in the presence of Mr. Shahnoor Malik (Principal) and observed that building comprised of basement, ground plus four upper floors.

Following shortcomings were observed during time of inspection:

1. Two staircase of width 1.50 & 1.35 meter are provided instead of required width of 1.50 meters each.
2. Width of corridor 1.50 meters is required to be provided.
3. Manually operated electrical fire alarm (MOEFA) is required to be provided at suitable location on each floor of the building.
4. The sprinkler system is required to be provided in basement area.
5. A down comer shall be provided on every floor containing two length (15 meters each) having 100 mm diameter.
6. Overhead tank of 5,000 liters capacity is provided against the requirement of 25,000 liters.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR

o/c DELHI FIRE SERVICE
w

Copy to:-

1. The Director of Education, MCD Udyog Sadan, Plot No. 419, FIE, Patparganj, Delhi - 110092.