

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No: F.6/DFS/MS/Hospital/2024/SZ/ 611

Dated: 04/11/2024

To,

The Authorized Signatory,
M/s Mata Roop Rani Maggo Hospital, A-1/25,
Opposite Metro Pillar No. 630, Janakpuri, New Delhi-110058.

Sub: - Regarding issuance of Fire Safety Certificate in r/o. M/s Mata Roop Rani Maggo Hospital situated at A-1/25, Opposite Metro Pillar No. 630, Janakpuri, New Delhi-110058.

Sir,

This has reference to your Letter No. Nil dated 15.10.2024, on the subject cited above. In this connection this is to inform you that officers concerned of this department inspected the hospital building on dated 25.10.2024 to verify the fire safety arrangements in accordance with the Rules. At the time of inspection Dr. Aman Maggo was present and it was observed that the hospital building is comprised of Basement (OPD, X-ray & Ultrasound), Ground floor (Patient's rooms & Cafeteria), Upper ground floor (Patient's rooms), First floor (Patient's ward & rooms), Second floor (OTs, NICU & Patient's rooms), Third floor (ICU & Patient's rooms) and have following shortcomings.

1. 02 staircase having width of 2.0 & 1.40 m found provided against requirement of 02 staircase having width of 2.0 & 1.50 m from basement to terrace level. Both staircases should be continuous up to terrace.
2. Fire check doors found not provided.
3. Drop Cartain found not provided in lift lobby.
4. Ventilation system found not provided in basement.
5. Hose reels/hydrant found provided but not functional.
6. Sprinkler system should be extended in left out area.
7. Underground fire pumps found not functional.
8. Underground water storage tank dimension/measurement and capacity should be provided.
9. Detail measurement of the underground water storage tank should be provided.
10. Exit Signs & lift signs found not provided.

Keeping in view of above, issuance of Fire Safety Certificate can-not be considered at this stage. You are requested to rectify the above shortcoming under the intimation to this department for further course of action.

Yours faithfully,

(Atul Garg)
Director
Delhi Fire Service

Copy to: -

1. MS, Nursing Homes, DGHS, Govt of NCT of Delhi, S-1, 3rd Floor, School Block, Shakarpur, Delhi-110092.
2. Executive Engineer (Bldg.), MCD, West Zone, Dr. Sahib Singh Varma Nigam Bhawan, Second Floor, Shivaji Enclave, New Delhi-110027 for information and to check the use of basement and other floors for the respective use, whether it is permissible or not.