

C/117



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No. F6/DFS/MS/2024/School/ 771

Dated: 14/11/2024

To,
The Principal,
O.P Suri Memorial Society (The Srijan School)
Plot No. 4B, North Model Town, Delhi-09.

Sub: - Regarding issuance of fire safety certificate in r/o O.P Suri Memorial Society (The Srijan School) located at Plot No. 4B, North Model Town, Delhi-110009.

Sir,

Please refer to your letter nil dated 04.10.2024 received in this department vide outdoor dairy no.7543 dated 08.10.2024 on the subject cited above. In this connection this is to inform you that the above mentioned site was visited by the officer concerned of this department on 09.11.2024 to check the existing fire safety measures. During inspection it has been observed that the school premise is comprised of ground & 04 upper floors. At the time of inspection Mr. Devashish Tiwari (Admin Officer) was also present at site. During the course of inspection the observations/ shortcomings made are as under:-

1. Fire check doors found removed at some places.
2. Hose reel hose is provided but not functional.
3. Internal hydrant is provided but not functional.
4. Terrace level fire pump capacity of 900lpm is provided but not functional.
5. Terrace level fire water tank capacity of 20,000ltr is provided and 5,000ltr water tank found removed at site.
6. Exit, floor & lift signage's found removed at strategic locations in the school building.
7. Electrical panel below in staircase needs to be removed/shifted in a safer place.
8. Two staircases from ground to terrace level found obstruct by combustible old damaged furniture material/ highly flammable & risk of life needs to be removed.

Keeping in view of above, renewal of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of school building is at your own risk & responsibility.

Yours faithfully

(Atul Garg)
Director

Ph:-011-23414000

Copy to:-

1. The Dy. Director of Education/ PSB Director, Education (Private School Branch), Government of N.C.T of Delhi. Old Secretariat, Delhi - 110054.