

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F.6/DFS/MS/2024/SZ/ 609
To

Dated: 04/11/2024

M/s Sri Sharada Institute,
Indian Management Research Foundation
Jagadguru S.M.S at 7 Institutional Area,
Phase-II, Vasant Kunj, New Delhi

Sub: Regarding issuance of Fire Safety Certificate in r/o Sri Sharada Institute of Indian Management Research Foundation of Jagadguru S.M.S at 7 Institutional Area, Phase-II, Vasant Kunj, New Delhi

Sir,

This has reference with the letter no nil dated nil received through outdoor diary no 7595 dated 08/10/2024 on the subject cited above. In this connection, the premise have been inspected by officer concerned of this department on 23/10/2024 in the presence of Mr. Soman to verify the present status of fire safety measures installed in the building. The fire safety arrangements were tested / checked and found following observations:-

1. The fire check door not provided in the staircase, lift lobby & basement.
2. Ventilation system not provided in the basement and upper floors.
3. Automatic Sprinkler System not working in the basement and upper floors.
4. Yard hydrant not provided.
5. Electrical fire pumps capacity 1620 LPM, Diesel Engine pump 1620 LPM provided against the required capacity for Electrical Fire Pump capacity 2850 LPM, Diesel Engine Pump 2850 LPM not provided.
6. Exit signage not provided.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to: -

1. The Jt. Director (S&E) Building, DDA, Bldg Section, Vikas Sadan, INA, New Delhi