



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

C-11
7/11/24
आज़ादी का
अमृत महोत्सव

No. F6/DFS/MS/School/NDZ/2024/762

Dated: 11/11/2024

To,

The Principal,
Sugam Public School
E - 43, Gali No. 15, Madhu Vihar,
Delhi - 110092.

**Subject: - Regarding grant of Fire Safety Certificate in r/o Sugam Public School located at E-43,
Gali No. 15, Madhu Vihar, Delhi - 110092.**

Sir,

This has a reference to your Outdoor Dairy No. 77526 dated 08.10.2024, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 29/10/2024 in the presence of Mr. K.K. Sharma (Manager) and observed that building comprised of basement (Store) + ground + four upper floors (School is running on G + 2 upper floors only),

Following shortcomings were observed during time of inspection:

1. First-Aid-Hose Reel not provided.
2. Fire pump of 220 LPM not provided.
3. Over head water storage tank of 25, 00 liters capacity required exclusively for firefighting is not provided.
4. Exit & floors Signage's not provided in strategic location in the building.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

O/C

(W)

Copy to:-

1. The Dy. Director of Education, Department of Education, MCD, Distt. North East, Shahdara, Delhi - .
2. The Manager, Sugam Public School located at E-43, Gali No. 15, Madhu Vihar, Delhi - 110092.