



No. F6/DFS/MS/EH/NDZ/2024/ 499

Dated: 08/11/2024

To,

Mr. Piyush Chadha (Owner),  
M/s Taste Masters,  
C - 59, First, Second & Third floors,  
Vikas Marg, Preet Vihar,  
Delhi - 110092.

C-51

**Sub: - Regarding grant of Fire Safety Certificate in r/o M/s Taste Masters located at C - 59, first, Second & Third floors, Vikas Marg, Preet Vihar, Delhi - 110092.**

Sir,

This has a reference to your MHA Portal application No. 2024092514803 dated 10/10/2024, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 29/10/2024 in the presence of Mr. Piyush Chadha (Owner), and observed that building comprised of basement, ground plus three upper floors, (basement (vacant), ground floor (Shop), Restaurant running on first floor, Second floor & third floor only.

**Following shortcomings were observed during time of inspection:**

1. Smoke management system is not provided.
2. MOEFA provided but not functional.
3. Internal Hydrants provided but not functional.
4. Pumping arrangements of one electric pump of 2280 LPM, one jockey pump of 180 LPM and one diesel pump of 2280 LPM fire pump not provided.
5. Fire Underground water tank of capacity 1,00,000 liters not provided.
6. Exit & floors Signage's not provided at strategic location in the building.

In view of above shortcomings, the application for issuance for Fire Safety Certificate at this stage is rejected.

Yours faithfully,

(ATUL GARG)  
DIRECTOR

o/c DELHI FIRE SERVICE

Copy to: -

1. Mr. Piyush Chadha (Owner), M/s Taste Masters, C-59, First, Second & Third floors, Vikas Marg Preet Vihar, Delhi-110092.
2. The Joint Commissioner of police (Lic), 1<sup>st</sup> Floor, P. S. Defence Colony, New Delhi-110024.  
w.e.f.- MHA Portal application No. 2024092514803 dated 10/10/2024.