



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**



No. F6/DFS/MS/2024/Metro/ 26

Dated: 18 / 11 / 2024

To

Sh. Shailendra Kumar (AGM/Elect./RC-1)  
 Mukundpur Depot Cum Workshop of Ph-III,  
 Delhi Metro Rail Corporation of Delhi.

**Sub:** - Regarding issuance of fire safety certificate in r/o Newly Construction Mukundpur Depot Cum Workshop of Ph-III of DMRC, Delhi.

Sir,

This has reference to your letter received through online e-mail dated 22.10.2024 on the subject cited above. In this connection this is to inform you that the above mentioned site was visited by the officer concerned of this department on 11.11.2024 to verify the fire safety arrangements provided therein as per the NBC Part-IV/UBBL-2016. At the time of inspection Sh. Azim (Asst. Section Engg.) was also present at site and said building was comprised of ground & 02 upper floors only. Your request for FSC is rejected under Rule 35 due to following shortcomings.

1. Smoke management system is not provided.
2. Smoke detector system & main panel is not provided.
3. Sprinklers system is not provided in storage area.
4. Exit & floors signage's not provided at strategic location in the building.

Keeping in view of above, grant of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of depot cum workshop is at your own risk & responsibility.

Yours faithfully

(Atul Garg)  
 Director  
 Ph:-011-23414000

14/11