



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

7/10/24 DPA+FT  
आज्जादी का  
अमृत महोत्सव

No. F6/DFS/MS/Hospital/2024/NDZ/2415

Dated: 28/10/2024

114

To,

Dr. M.K Saxena (Medical Director),  
Apex Citi Hospital  
D – 440, west Vinod Nagar,  
Near Ras Vihar, I.P Extension,  
Patparganj, Delhi - 110092.

**Subject: - Inspection Report in r/o M/s Apex Citi Hospital located at D – 440, west Vinod Nagar, Near Ras Vihar, I.P extn., Patparganj, Delhi - 110092.**

Sir,

Please refer to your outdoor diary no. 7325 dated 03/10/2024 on the subject cited above. In this connection, it is to inform you that the site was visited by officers concerned of this department on dated 24/10/2024 and observed that the shortcoming has still not complied with as issued by this department vide letter no. F6/DFS/MS/Hospital/2016/1554 dated 16/06/2016 (copy enclosed).

In view of above, the application for issuance of Fire Safety Certificate is rejected. The occupancy of the building / premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner / occupier.

Yours faithfully,

Enclosed: As above

(ATUL GARG)  
DIRECTOR

o/c DELHI FIRE SERVICE

Copy to: -

1. Dr. M.K Saxena (Medical Director), Apex Citi Hospital located at D – 440, west Vinod Nagar, Near Ras Vihar, I.P extn., Patparganj, Delhi - 110092.
2. The Medical Superintendent, Nursing Homes, Directorate General of Health Services, Govt. of NCT of Delhi, 3<sup>rd</sup> floor, Delhi Govt. Dispensary Building, S-1, School Block, Shakarpur, Delhi – 110032.

92

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE**  
**NEW DELHI- 110001**

No. FG/DFS/MS/HOSPITAL/2016/1554

Dated: 16/6/16

To,

Dr. M.K.Sexena

Apex Citi Hospital

D-440, West Vinod Nagar, Hanuman Road, Delhi-92

Sub: - Regarding NOC for Apex Citi Hospital located at D-440, West Vinod Nagar,  
Hanuman Road, Delhi-92

Sir,

Please refer to letter dated 16.02.2016 on the subject cited above. In this connection this is to inform you that officer concerned of this department inspected the Hospital to verify the fire safety arrangements in accordance with the 33 of the Delhi Fire Service Rule, 2010. At the time of inspection Dr.M.K.Sexena was also present and it was observed that the Hospital building is comprised of lower ground, ground plus three upper floors. The following shortcoming was observed:-

1. The width of main staircase is 1.70 m against the required width of 2 m.

In view of above, the fire safety certificate cannot be issued at this stage. Therefore you are requested to rectify the above said shortcoming under intimation to this department for further course of action.

Yours faithfully

  
(Virendra Singh)

Dy. Chief Fire Officer

o/c 

