



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001



46

No.F6/DFS/MS/2024/Incl./ 2518

Dated 14/11/2024

To

The Authorized Signatory
Divine Autotech Pvt. Ltd at Plot No-26,
Rajasthani Udhyog Nagar, G.T. Karnal,
Road, Industrial Area, Delhi-110033.

Sub: Regarding issuance of Fire Safety Certificate in r/o Divine Autotech Pvt. Ltd located at Plot No-26, Rajasthani Udhyog Nagar, G.T. Karnal Road, Industrial Area, Delhi-110033.

Sir,

Please refer to your letter no. nil dated 23.10.2024 received in this department vide outdoor dairy no-8342 dated 25.10.2024 on the subject cited above. In this connection this is to inform you the aforesaid building was inspected by the officers concerned of this department on 06.11.2024 in the presence of Sh. Hariom (Owner) to verify the status of the shortcomings already issued by this department vide letter No.F6/DFS/MS/2024/Incl./534 dated 19.09.2024 and status is as under: -

S No.	Shortcomings	Status
1.	One fire check door is required.	Not Complied
2.	MOEFA system is not provided.	Not Complied
3.	Smoke ventilation system is not provided in the building.	Complied
4.	Terrace level fire water tank capacity of 25,000ltr is provided against the requirement of 50,000ltr.	Not Complied
5.	Exit signage's and floor signage is not provided at strategic location in the building.	Not Complied
6.	Standby power supply is not provided.	Not Complied
7.	Building is not constructed as per approved sanction plan.	Not Complied

Keeping in view of above observations, the said building is not safe from fire safety point of view. Hence, you are hereby advised to comply the observations at the earliest under intimation to this department. Any loss of life and property untoward mishap due to non-compliance of the fire safety measures in the event of fire and other emergency the management is solely responsible.

Yours faithfully

(Atul Garg)
Director

Ph:-011-23414000

17/11

Copy to:-

1. The Dy. Commissioner of Factory licensing, SDMC 3rd, Floor, Civic Centre Minto Road, Delhi-110002.