

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001**

No.F6/DFS/MS/NDZ/2024/college/368

Dated:-14/11/2024

To

The Authorized Signatory ,  
Institute for integrated Learning in Management ( Educational building) at plot no. 60, 61 & 62  
Rouse Avenue, DDU Marg , New Delhi.

**Sub: Application for renewal of Fire Safety Certificate (FSC) in r/o Institute for integrated Learning in Management (Educational building) at plot no. 60, 61 & 62 Rouse Avenue, DDU Marg, New Delhi.**

Sir,

This has a reference to your letter no. nil dated 03.10.2024 on the subject cited above. In this regard, this is to inform you that the site was inspected by officers concerned of this department on 08/11/24 in the presence of Sh. Rajeev, Admin Head and following shortcomings were observed:

1. FCD found removed from Lift lobby in basement.
2. Pressurization found nonfunctional fire tower lift lobby.
3. Diesel pump is not auto start provision.
4. Lift signages found removed.
5. Pantry is not allowed in fire tower lift lobby, same shall be removed.

In view of above, the case is rejected and fire safety certificate (FSC) cannot be issued at this stage. Further, the occupancy of building /premises in absence requisite fire & life safety arrangements shall be at the risk and liability of the owner/occupier. The statutory/licensing authority may take suitable action as deemed fit

Yours faithfully



(Atul Garg)  
DIRECTOR  
01123414000

**Copy to :**

1. The Commissioner , MCD , Civic Centre , New Delhi.