

99

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/SZ/2024/ 614

Dated: 05/11/2024

To,

The Authorized signatory,
Singhal Hospital,
C-40, Street No. 9, Sadh Nagar, Palam Colony,
New Delhi - 110045.

Subject: Issuance of Fire Safety Certificate in r/o Singhal Hospital Located at C-40, Street No. 9, Sadh Nagar, Palam Colony, New Delhi – 110045.

Sir,

Please refer to your letter No. 15/24 dated 12/09/2024 on the subject mentioned above. In this connection it is to inform you that the premises was inspected by the officers concerned from this department on 23/10/2024 in presence of Dr. Pankaj from fire safety point of view..

During course of inspection the following shortcomings are observed:

1. Two staircases of 2m & 1.5m clear width found not provided.
2. Exit doors 2m for general ward, ICU & 1.2m for Patient rooms having less than 3 beds found not provided.
3. Corridor of 2.4m clear width found not provided.
4. Fire check doors found not provided.
5. Automatic fire detection system not provided.
6. MOEFA & PA system not provided.
7. Automatic sprinkler system not provided.
8. Capacity of main pump, stand by pump & jockey to be informed.
9. Capacity & dimension of underground tank to be informed.
10. Overhead tank of capacity 5000 ltr not provided.
11. Exit Signage not provided at some places.

In view of the above shortcomings issuance of Fire Safety Certificate cannot be considered at this stage. You are requested to comply the abovementioned shortcomings under intimation to this department for further consideration in the matter.

(Atul Garg)
Director
Delhi Fire Service

ok 
23/10/24

Copy to:-

1. The MS, Nursing Homes, Directorate General of Health Services, Govt. of NCT of Delhi, S-1, 3rd floor, School Block, Shakarpur, Delhi – 110092.
2. The Joint Director (L&I) Bldg. DDA, Vikas Sadan, INA, New Delhi.