

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001

No. F.6/DFS/MS/GH/2024/SZ/687
To

Dated: 14.../11.../2024

The Joint Commissioner of Police,
Lic/Branch, 1st Floor, P.S Defence Colony,
New Delhi 110049

Sub: Regarding issuance of FSC in r/o M/s Hotel Castle Blue, at Plot No A-109, Road no 5, Mahipalpur Extn. New Delhi-110037

Sir,

This is in reference with **MHA Portal ID 2024101615762 dated 16/10/2024** on the subject cited above. In this connection, it is inform you that the premises have been inspected by officer concerned of this department on 12/11/2024 in the presence of Mr. Rajesh Kumar of the Guest House. During the inspection, it was observed that the guest house is running at Ground + 03 Upper Floor. The shortcomings observed are as below;

1. The occupancy above 3rd floor is not allowed as per clause 7.31 of UBBL 2016.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

elmc