

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001

No. F.6/DFS/MS/GH/2024/SZ/688
To

Dated: 14/11/2024

The Joint Commissioner of Police,
Lic/Branch, 1st Floor, P.S Defence Colony,
New Delhi 110049.

Sub: Regarding issuance of FSC in r/o M/s The Venue located at Plot No K-17, Kh. No 725, old Rangpuri Road, Mahipalpur, Delhi

Sir,

This has reference with **MHA Portal ID 2024101515708 Dated 19/10/2024 & MHA Portal ID 2024102115917 dated 23/10/2024** on the subject cited above. In this connection, the premises have been inspected by officer concerned of this department on 13/11/2024 in the presence of Mr. Deepak Rawat. During the inspection, it was observed that the building comprised of Basement + Ground + 05 upper floors. Accordingly fire safety arrangement were tested / checked and found following observation.

1. Fire Check door not provided as per clause 7.31 of UBBL 2016.
2. Smoke ventilation system provided but found not working.
3. First aid hose reel provided but found non functional.
4. Carbon Monoxide detector provided but found not working.
5. Internal hydrant provided but found not working.
6. Terrace level pumps capacity 900 LPM provided but found non-functional.
7. Overhead tank capacity 4,000 ltrs provided against the required capacity 15,000 ltrs.
8. Exit signage not provided.
9. The occupancy above 3rd floor is not allowed as per clause 7.31 of UBBL 2016.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully,

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

[Handwritten signature]