

C/142

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No.F6/DFS/MS/NDZ/2024/ 508

Dated: 11/11/2024

To

The Manager,
M/S Wow Restaurant (Desire Infrastructure Pvt. Ltd.)
L-22, Connaught Place, New Delhi.

Sub: Regarding grant of FSC in r/o M/S Wow Restaurant (Desire Infrastructure Pvt. Ltd.) located at L-22, Connaught Place, New Delhi.


Sir,

This has reference to ID No 2024101915879 dated 19/10/24, on the subject cited above, it is to inform you that the site was inspected by the officer concerned of this department on 11/11/24 in the presence of **Manager** and the following shortcomings were observed:-

1. Hose reel found nonfunctional.
2. Pump found nonfunctional.
3. Alternate exit found blocked.

In view of above, the case is rejected and Fire Safety Certificate (FSC) cannot be renewed at this stage. Therefore, you are requested to rectify the above shortcomings and re-submit for further consideration in the matter.

Yours faithfully


(Anil Garg)
DIRECTOR
Delhi Fire Service

Copy to:-

The Addl. Commissioner of Police (Lic.), Licensing Unit, Defense Colony Police Station,
New Delhi.