



No. F6/DFS/MS/School/NDZ/2024/ 782

Dated: 22/11/2024

To,

The Principal,
MCD Primary School
Trilok Puri – 16 Block,
Delhi - 110092.

Subject: - Regarding grant of Fire Safety Certificate in r/o MCD Primary School located at Trilok Puri – 16 Block, Delhi - 110092.

Sir,

This has a reference to email dated 18/10/2024, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 11/11/2024 in the presence of Mrs. Sabha Noor (Principal) and observed that building comprised of two blocks interconnected, Block A- ground plus one upper floor & Block B- ground plus two upper floors only.

Following shortcomings were observed during time of inspection:

1. One Additional staircase of width 1.50 meters is required in block - B.
2. First-Aid-Hose Reel not provided.
3. MOEFA not provided.
4. Down Comer not provided.
5. Fire pump of 450 LPM not provided..
6. Overhead tank of capacity 10,000 liters not provided.
7. Exit & floors Signage's not provided in strategic location in the building.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

Copy to:-

1. The Joint Director of Education, MCD, Udyog Sadan, Plot No.419, FIE, Patargang, Delhi - 110092.