

c/23

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE

NEW DELHI- 110001

No. F6/DFS/MS/School/2024/SZ/ 779

Dated: 22/11/2024

To,

The Manager,
M.D.R. Public School,
Satyam Puram, Jharoda Kalan, New Delhi- 110072.

Sub: -Regarding renewal of "FSC" from fire safety point of view in r/ M.D.R. Public School at Satyam Puram, Jharoda Kalan, New Delhi- 110072.

Sir,

Please refer to your letter No. MDR/10/24 dated 24.10.2024, on the subject cited above. In this connection, it is to inform you that officer concerned of this department inspected the school building on dated 14.11.2024 in the presence of Mrs. Radha Rani (Owner), to verify the fire safety arrangements in accordance with the rules.

At the time of inspection, it was observed that the school building comprised of ground plus two upper floors and following shortcomings were observed: -

1. Hose reels/hydrant found not provided.
2. Terrace Fire pump capacity of 450 LPM found not provided.
3. Overhead water storage tank capacity of 10,000 ltrs found not provided.
4. Exit signage's are found not provided.

In view of the above, fire safety certificate cannot be considered at this stage. Therefore, you are requested to rectify the above said shortcomings under the intimation to this department for further necessary action in the matter and running school in absence of requisite fire safety arrangements shall be at the risk & liability of the owner/occupier.

Yours faithfully


(Atul Garg)
Director
Delhi Fire Service

Copy to: -

1. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi - 110054.

: - for necessary action please.