



No. F6/DFS/MS/School/NDZ/2024/ 784

Dated: 25/11/2024

To,

The Principal,
Nigam Pratibha (Co - Ed.) Vidyalaya
Mahila Colony, Delhi - 110031.

Subject: - Regarding grant of Fire Safety Certificate in r/o Nigam Pratibha (Co - Ed.) Vidyalaya located at Mahila Colony, Delhi - 110031.

Sir,

This has a reference to Outdoor Dairy No. 8154 dated 22/10/2024, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 14/11/2024 in the presence of Mr. Pankaj Tyagi (Incharge) and observed that building comprised of ground plus two upper floors.

Following shortcomings were observed during time of inspection:

1. First-Aid-Hose Reel at each floors provided but not functional.
2. Fire pump of 450 LPM provided but not functional
3. Over head water storage tank of 10,000 liters capacity required exclusively for firefighting is found removed.
4. Exit & floors Signage's not provided in strategic location in the building.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR

o/c DELHI FIRE SERVICE

Copy to:-

1. The Joint Director of Education, MCD, Udyog Sadan, Plot No.419, FIE, Patargang, Delhi - 110092.