

C/32



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No.F6/DFS/MS/School/SZ/2024/783

Dated: 25/11/2024

To

The Principal,
R.S. Convent Public School,
60 Feet Road, Molarband Extn.,
Badarpur, New Delhi.

Sub:- Regarding renewal of Fire Safety Certificate in respect of M/s R.S. Convent Public School located at 60 Feet Road, Molarband Extn., Badarpur, New Delhi.

Sir,

With reference to the letter bearing outdoor diary no. 14564 dated-22.03.2024 on the subject cited above, it is informed that the school building was inspected by Assistant Divisional Officer (M. Road) from this department on 19.11.2024 in the presence of Mrs. Ritu Jain (Teacher) and it was observed that the building which was earlier comprised of ground + 01 upper only is now comprised of Ground + 02 upper floors. Hence is a case addition/alteration. During the inspection following shortcomings were observed:-

1. 2 nos. of staircases width of 1.50 meters each shall be provided.
2. 06 nos. of fire extinguishers shall be provided.
3. Hose reel shall be provided in each floor.
4. Fire pump having capacity 450 LPM & head 40 mtrs. shall be provided.
5. Overhand tank capacity of 10,000 ltrs shall be provided for fire fighting.
6. Exit signages shall be provided.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the school management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


(Atul Garg)
Director

Delhi Fire Service

24/11/24

Copy to:-

1. The Dy. Director of Education, GNCT of New Delhi DISST. South Block-C, Defence Colony, New Delhi-24.