

c/6

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE

NEW DELHI- 110001

No. F6/DFS/MS/Banquet/2024/SZ/ 129

Dated: 21/11/2024

To,
The Joint C.P. (Lic.),
1st floor, Police Station,
Defence Colony, New Delhi.

Sub: - Regarding issuance of "FSC" in respect of M/s. Green Apple Banquet at A-1 & A-2, Kh. No. 8/16, Shyam Vihar, Ph-1, Najafgarh, New Delhi- 110043.

Sir,

Please refer to online application ID 2024102316054 dated 28.10.2024, on the subject cited above. In this connection, it is to inform you that officer concerned of this department inspected the banquet hall building on dated 18.11.2024 in the presence of Mr. Gosai (Manager) to verify the fire safety arrangements in accordance with the rules.

At the time of inspection, it was observed that the banquet hall running at first floor only of a building comprised of ground and first floor only, and have following shortcomings were observed: -

1. Fire Check doors found not provided.
2. Hose reels/hydrant system found provided but not functional.
3. Terrace fire pump of 900 LPM found provided but not functional.
4. Exit signage's are found not provided at banquet hall area.

In view of above, issuance of fire safety certificate cannot be considered at this stage. Management of banquet hall may be requested to rectify the above said shortcomings under the intimation to this department for further necessary action in the matter and running banquet hall in absence of requisite fire safety arrangements shall be at the risk & liability of the owner/occupier.

Yours faithfully


(Atul Singh)
Director

Delhi Fire Service

Copy to: -

1. The owner/occupier, M/s. Green Apple Banquet at A-1 & A-2, Kh No. 8/16, Shyam Vihar, Ph-1, Najafgarh, New Delhi- 110043.